

FM Approval Guide - January 2008

January 2008 — Approval Guide
Automatic Sprinkler Systems

1-181

Rapidrop Limited, Manasty Road, Peterborough PE2 6UP, United Kingdom

<i>Product Designation</i>	<i>Description</i>	<i>Nominal Pipe Size, in.</i>	<i>Max Working Pressure, psi (kPa)</i>	<i>Remarks</i>
FCG 300	Swing Check Valve, Grooved Ends	2, 2½, 3, 4, 6, 8	300 (2070)	a

a. Resilient Seat.