

FM Approval Guide – January 2008

January 2008 — Approval Guide
Automatic Sprinkler Systems

1-85

Rapidrop Limited, Rutland Business Park, Newark Road, Peterborough PE1 5WA, United Kingdom

<i>Model</i>	<i>NPT in.</i>	<i>Hose Assembly length ft (m)</i>	<i>Equivalent Length of 1 in. Schedule 40 Pipe, ft (m)</i>
Rapidrop® -SPB-01A-NPT	½	2.5 (0.7)	14.6 (4.5)
Rapidrop® -SPB-02A-NPT	½	4 (1.2)	28.0 (8.5)
Rapidrop® -SPB-03A-NPT	½	5 (1.5)	50.2 (15.3)
Rapidrop® -SPB-04A-NPT	½	6.2 (1.8)	53.5 (16.3)
Rapidrop® -SPB-05A-NPT	½	8.3 (2.5)	67.1 (20.4)
Rapidrop® -SPNB-01A-NPT	½	2.5 (0.7)	14.6 (4.5)
Rapidrop® -SPNB-02A-NPT	½	4 (1.2)	28.0 (8.5)
Rapidrop® -SPNB-03A-NPT	½	5 (1.5)	50.2 (15.3)
Rapidrop® -SPNB-04A-NPT	½	6.2 (1.8)	53.5 (16.3)
Rapidrop® -SPNB-05A-NPT	½	8.3 (2.5)	67.1 (20.4)
Rapidrop® -SPWB-01A-NPT	½	2.5 (0.7)	14.6 (4.5)
Rapidrop® -SPWB-02A-NPT	½	4 (1.2)	28.0 (8.5)
Rapidrop® -SPWB-03A-NPT	½	5 (1.5)	50.2 (15.3)
Rapidrop® -SPWB-04A-NPT	½	6.2 (1.8)	53.5 (16.3)
Rapidrop® -SPWB-05A-NPT	½	8.3 (2.5)	67.1 (20.4)
Rapidrop® -SPB-01B-NPT	¾	2.5 (0.7)	20.7 (6.3)
Rapidrop® -SPB-02B-NPT	¾	4 (1.2)	32.1 (9.8)
Rapidrop® -SPB-03B-NPT	¾	5 (1.5)	48.4 (14.7)
Rapidrop® -SPB-04B-NPT	¾	6.2 (1.8)	56.6 (17.2)
Rapidrop® -SPB-05B-NPT	¾	8.3 (2.5)	77.1 (23.5)
Rapidrop® -SPNB-01B-NPT	¾	2.5 (0.7)	20.7 (6.3)
Rapidrop® -SPNB-02B-NPT	¾	4 (1.2)	32.1 (9.8)
Rapidrop® -SPNB-03B-NPT	¾	5 (1.5)	48.4 (14.7)
Rapidrop® -SPNB-04B-NPT	¾	6.2 (1.8)	56.6 (17.2)
Rapidrop® -SPNB-05B-NPT	¾	8.3 (2.5)	77.1 (23.5)