



Certificate of Compliance

This certificate is issued to Rapidrop Ltd. for the following equipment:

SPRINKLER SYSTEM ALARM TESTER

Model TDV: 1 and 1-1/4 in. NPT female threaded inlet with male threaded outlet.
1/2 in. nominal orifice and 175 psi (1205 kPa) rated working pressure.

FM Approvals confirms that the items have been found to comply with the Approval Standard
Class Number 1625.

PRIVATE LABELER

RAPIDROP LTD.

MANASTY ROAD, PETERBOROUGH

CAMBRIDGE PE2 6UP

UNITED KINGDOM

Project Identifier: 3033325

Date of Private Labeler Agreement: May 14, 2008

A handwritten signature in black ink, appearing to read 'Richard B. Dunne'.

Richard B. Dunne,
Group Manager-Hydraulics

July 25, 2008

Date: July 25, 2008



Member of the FM Global Group